



Sl.No.	Description	UOM	Admin Block	Main Block	Primary Block	Hostel Block	Total
1	Hose Reel Drums Complete Set	No's	20	8	0	0	<b>28</b>
2	Hose Reel Drum Only	No's	0	0	1	1	<b>2</b>
3	Shut-off Nozzle	No's	0	2	8	8	<b>18</b>
4	Alaram Panel (4-Zone)	No's	0	0	0	0	<b>0</b>
5	Alaram Panel (3-Zone)	No's	0	1	0	0	<b>1</b>
6	Alaram Panel (2-Zone)	No's	0	0	1	1	<b>2</b>
7	MCP	No's	9	10	8	0	<b>27</b>
8	Hooters	No's	4	10	8	0	<b>22</b>
9	2 Core X 1.5mm Cable	mtr	0	300(approx)	200 (approx)	0	<b>500</b>
10	Electrical Panel	No's	0	2	1	0	<b>3</b>
11	3Core X 6sq mm Cable	Mtr	0	80(approx)	50(approx)	0	<b>130</b>
12	Ms-B-Class Pipe	Mtr	0	0	0	6	<b>6</b>
13	Hydrant Valve	No's	0	0	2	0	<b>2</b>
14	Branch Pipe	No's	0	0	2	7	<b>9</b>
15	Hose Box	No's	0	0	2	0	<b>2</b>
16	CP Hose	No's	0	0	2	0	<b>2</b>
17	Ball Valve(set)	No's	0	0	8	0	<b>8</b>
18	Butterfly Valve	No's	0	3	1	0	<b>4</b>
19	Booster Pump	No's	0	0	0	0	<b>0</b>
20	Fire Brigade Inlet	No's	0	1	1	0	<b>2</b>
21	Hydrant Valve Blank Cap	No's	5	0	0	0	<b>5</b>
22	Hydrant Valve Wheel	No's	1	0	0	1	<b>2</b>
23	Hydrant Valve Nut	No's	1	0	0	1	<b>2</b>
24	Hydrant Valve Rubber Washer	No's	1	0	0	0	<b>1</b>

**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : ADMIN BLOCK (Wet Riser, Opp:Purchase Dept.) - Cellar+Ground+4 Floors**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	BUTTERFLY VALVE	BOOSTER PUMP	ELECTRICAL PANEL	MCP	HOOTER	ALARAM PANEL	REMARKS					
Cellar	Required	Required	Required	Working	Nut Required	Working	Working	Working	Working	Working	Working	Working	Working	Working	Need to install complete New Hose Reel Drum set in all floors except 4th floor					
Ground Floor	Required	Required	Required	Working	Working	Working	Working	Working				Required	Required							
First Floor	Required	Required	Required	Working	Working	Working	Working	Working				Working	Working			Working	Working	Working	Alaram Panel Zone:1Problem (need to be rectfied)	
Second Floor	Required	Required	Required	Working	Working	Working	Working	Working				Working	Working			Working	Working	Working		
Third Floor	Required	Required	Required	Working	Working	Working	Working	Working				Working	Working			Working	Working	Working		
Fourth Floor	Working	Working	Working	Working	Working	Working	Working	Working				Working	Working			Working	Required	Required	Working	Need to install new MCP & Hooter with wiring in 4th floor
Terrace																				

**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : ADMIN BLOCK (Wet Riser, Middle of the Block) - Cellar+Ground+4 Floors**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	BUTTERFLY VALVE	ELECTRICAL PANEL	MCP	HOOTER	ALARAM PANEL	REMARKS					
Cellar	Required	Required	Required	Working	Wheel required	Working	Working	Working	Working	Working	Required	Working	Working	Alaram Panel Zone:2Problem (need to be rectfied)					
Ground Floor	Required	Required	Required	Working	Working	Working	Working	Working			Working	Working							
First Floor	Required	Required	Required	Working	Working	Working	Working	Working			Working	Working			Working	Working	Working	Need to install complete New Hose Reel Drum set in all floors except 4th floor	
Second Floor	Required	Required	Required	Working	Working	Working	Working	Working			Working	Working			Working	Working	Working		
Third Floor	Required	Required	Required	Working	Working	Working	Working	Working			Working	Working			Working	Working	Working		
Fourth Floor	Working	Working	Working	Working	Working	Working	Working	Working			Working	Working			Working	Required	Required	Working	Need to install new MCP & Hooter with wiring in 4th floor
Terrace																			



**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : MAIN BLOCK -WET RISER -1 - GROUND + 4 FLOORS**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	FIRE BRIGADE	BUTTERFLY VALVE	BOOSTER PUMP	ELECTRICAL PANEL	MCP	HOOTER	ALARAM PANEL	REMARKS								
Ground Floor									Need to Install New Fire Brigade Inlet with Piping	Required	Working	Manual System Available, need to change Automatic System	Need to Install New MCP with Wiring	Need to Install New Hooters with Wiring	Zone 3 Panel Required	Need to install complete New Hose Reel Drum set in all floors								
First Floor	Required	Required	Required	Working																			Need to change Wet Riser Pipe Line from 50mm dia to 100mm dia	
Second Floor	Required	Required	Required	Working																				
Third Floor	Required	Required	Required	Working																				
Fourth Floor	Required	Required	Required	Working	Working	Working	Working	Working																
Terrace																								

**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : MAIN BLOCK -WET RISER -2 - GROUND + 4 FLOORS**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	BUTTERFLY VALVE	BOOSTER PUMP	ELECTRICAL PANEL	MCP	HOOTER	ALARAM PANEL	REMARKS							
Ground Floor									Required	Working	Manual System Available, need to change Automatic System	MCP Wiring Required	Hooters Wiring Required	Zone 3 Panel Required	Need to change Wet Riser Pipe Line from 50mm dia to 100mm dia							
First Floor	Working	Working	Working	Working																		
Second Floor	Working	Working	Required	Working																		
Third Floor	Working	Working	Required	Working																		
Fourth Floor	Working	Working	Working	Working	Working	Working	Working	Working														
Terrace																						

**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : MAIN BLOCK -WET RISER -3 - GROUND + 4 FLOORS**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	BUTTERFLY VALVE				MCP	HOOTER	ALARAM PANEL	REMARKS							
Ground Floor									Required				Need to Install New MCP with Wiring	Need to Install New Hooters with Wiring	Zone 3 Panel Required	Need to install complete New Hose Reel Drum set in all floors							
First Floor	Required	Required	Required	Working																			
Second Floor	Required	Required	Required	Working																			
Third Floor	Required	Required	Required	Working																			
Fourth Floor	Required	Required	Required	Working	Working	Working	Working	Working															
Terrace																							



**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : HOSTEL BLOCK -WET RISER -1 - GROUND + 3 FLOORS**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	FIRE BRIGADE	BUTTERFLY VALVE	BOOSTER PUMP	ELECTRICAL PANEL	MCP	HOOTER	ALARAM PANEL	REMARKS
Ground Floor	Working	Working	Required	Working	Working	Working	Working	Required	Need to change Building Back-Side to Front Side	Working	Working	Working	Need to check after installation 2-Zone Alaram Panel	Need to check after installation 2-Zone Alaram Panel	Zone 2 Panel Required	
First Floor	Working	Working	Required	Working	Wheel Nut Required	Working	Working	Required								
Second Floor	Working	Working	Required	Working	Working	Working	Working	Required								
Third Floor	Working	Working	Required	Working	Wheel Required	Working	Working	Required								
Terrace																

**DELHI PUBLIC SCHOOL - NACHARAM**

**BLOCK : HOSTEL BLOCK -WET RISER -2 - GROUND + 3 FLOORS**

	HOSE REEL DRUM	HOSE REEL	SHUT OFF NOZEEL	BALL VALVE	HYDRANT VALVE	HOSE BOX	CP HOSE	BRANCH PIPE	FIRE BRIGADE	BUTTERFLY VALVE	MCP	HOOTER	ALARAM PANEL	REMARKS
Ground Floor	Working	Working	Required	Working	Working	Working	Working	Working	Need to change Building Back-Side to Front Side	Working	Need to check after installation 2-Zone Alaram Panel	Need to check after installation 2-Zone Alaram Panel	Zone 2 Panel Required	
First Floor	Working	Working	Required	Working	Working	Working	Working	Required						
Second Floor	Required	Working	Required	Working	Working	Working	Working	Required						
Third Floor	Working	Working	Required	Working	Working	Working	Working	Required						
Terrace														80mm dia MS-B-Class pipe Required